

**BID ADDENDUM**  
06/01/2009

**Carol Love**  
M/M Secretary

**(434) 792-5544 ext. 10**  
Telephone Number

**(434) 799-8249**  
Fax Number

[clove@drhava.com](mailto:clove@drhava.com)  
Email Address

## Danville Redevelopment and Housing Authority

135 Jones Crossing  
Danville, Virginia 24541  
[www.drhava.com](http://www.drhava.com)

**IFB #20090518**  
**Bid Due Date:**  
**Monday, June 15,**  
**2009**

### **BID ADDENDUM #3**

**Description: Roof Replacement/Repair  
At Cardinal Village and Cedar Terrace**

### **Bidders Note:**

Question #1 – Is replacing the gutters part of the package?

Answer #1 – No. Gutters are a separate package.

Question #2 – Leave the copper counter flashing to brick joints or replace it?

Answer #2 – Leave them. They will not be replaced at this time.

Question #3 – Leave or replace rusty heat stack vents?

Answer #3 – Replace them. Please include this in your bid by writing on the bid form below the other prices the price per heat stack vent replaced. (Example: “Each Heat Stack Vent Replaced - \$00”)

Please sign and return by fax to (434) 799-8249 (**preferred method**)

**OR**

Addendum must be *Signed & Returned* with your Bid.

\_\_\_\_\_  
*Authorized Signature of Bidder*

\_\_\_\_\_  
*Company Name*